


RESOURCE MANAGEMENT AGENCY
DEPARTMENT OF ENGINEERING
AND GENERAL SERVICES

2037 W. Cleveland Avenue
Mail B & C
Madera, CA 93637-8720
(559) 675-7817
FAX (559) 675-7639
Greg.farley@madera-county.com

S. Greg Farley PE, County Engineer

DATE: August 26, 2010

TO: Bidders

FROM: S. Greg Farley, Madera County Engineer 

SUBJECT: Revised Addendum #1 - CSA-1, Indian Lakes Pressure Filter Replacement

Addendum # 1 is here by replaced by this Revised Addendum #1.

1. The attendees of the mandatory Job walk on August 25, 2010 are as follows:

- Jess Travis – Travis Construction
- Ed Campbell – Western Water
- Justin Jones – Mosser Logging
- Justin Wood – Lyles
- James Labaugh – Precision Analytical
- Steve Norman – Madera County
- Marty Duvall – Madera County
- Julio Padilla – Madera County
- Loren Green – Madera County

2. Clarification: PLC changes are not a part of this project.

3. Correction: Section 1.03 "Contract Time" of the Instruction to Bidders reads:

- Perform the Work in sixty (100) working days including submittals, fabrication, construction and testing.

This section shall read:

- Perform the Work in **one hundred (100)** working days including submittals, fabrication, construction and testing.

4. Correction: The Bid Form under Section labeled "Contact Time". Reads:

- Complete the Work in sixty (60) working days from Notice to Proceed.

This section shall read:

- Complete the Work in **one hundred (100)** working days from Notice to Proceed.

5. Clarification: Buy American act is not a requirement of this project.

6. **Clarification:** Disinfection of the system will be the responsibility of the contractor. The County will verify residual, collect sample and have bacteriological test completed.

7. **Deletion:** Sheet 3 of the plans under Construction Notes reads:

- Contractor shall remove and lawfully dispose of all spoils material including Pressure filters, Media, Contact Tank, etc
- The Contact Tank shall be removed from this note. The Contact tank shall be salvaged.

8. **Correction:** Section 7.01 "Duration of Offer" of the Instruction to Bidders reads:

- A. Bids shall remain open to acceptance and shall be irrevocable for a period of thirty (30) days after the bid closing date.

This section shall read:

- A. Bids shall remain open to acceptance and shall be irrevocable for a period of **sixty (60)** days after the bid closing date.

9. **Correction:** Section 2.02 of the Instruction to Bidders Notice to Contractors reads:

- A. Bid Documents may be obtained at the office of Owner.
- B. Bid Documents can be obtained by bidders from Madera County Resource Management Agency, 2037 West Cleveland Avenue, Madera, CA 93637, upon receipt of a non-refundable deposit, by certified check or cash, in the amount of \$20.00 per set.

This section shall read:

- A. Bid Documents **shall** be obtained at the office of Owner.
- B. Bid Documents **shall** be obtained by bidders from Madera County Resource Management Agency, 2037 West Cleveland Avenue, Madera, CA 93637, upon receipt of a non-refundable deposit, by certified check or cash, in the amount of \$20.00 per set.

10. **Change:** On Sheet 4 of the Plans – Contractor shall construct butterfly valves on each side of the pressure relief valve for the purpose of isolation. Piping shall be cement lined Ductile Iron Pipe and painted to match existing pipe. 6-inch pipe may be used in lieu of 8-inch pipe to avoid reducers.


11. **Clarification:** On Sheet 4 of the Plans – Contractor shall construct butterfly valves on each side of the pressure relief valve for the purpose of isolation.

12. **Change:** The date of the Bid opening for this project is here by changed to **September 2, 2010 at 3:00pm**

13. **Attention:** The Specifications that were electronically available for viewing are missing the Madera County Master Contract 011 section. That master contract can be viewed at

<http://www.madera-county.com/supervisors/contracts.html>. The Specifications purchased from the Madera County RMA were not missing this section in the specifications.

- 14. Clarification:** The contractor shall make every effort to salvage the underlined drains in the tank. It will be the responsibility of the manufacture to verify if they are in acceptable condition to be reused.



S. GREG FARLEY, COUNTY ENGINEER

8-30-10

DATED